

Accessible Toilet specifications

Space

- Door clear opening including active leaf for double doors not less than 850mm (AS 1428.1 Clause 13.2)
- Sanitary facility circulation space is minimum 2300mm long x 1900mm wide (AS 1428.1 Clause 13.2)
- Wheelchair users can shut the door when in the cubical as hinged door opens away from the toilet.

Toilet

- Pan side offset is within range of 450-460mm and rear wall to front within range of 790-810mm (AS 1428.1 Clause 15.2.2)
- The height to top of pan seat is within range of 460-480mm (AS 1428.1 Clause 15.2.3)
- Pan seat is full round type and securely fixed or provide lateral stability (AS 1428.1 Clause 15.2.3 (b)(c))
- Pan seat has luminance contrast of 30% with the background e.g. pan, wall or floor (AS 1428.1 Clause 13.2.3 (e))
- Toilet paper holder is located next to toilet pan between 480mm & 700mm above floor level and no more than 300mm in front of pan
- Sanitary disposal units are located between 900-1100mm above floor level and within reach of toilet
- Flushing mechanism is easy to operate and no more than 1100mm above the floor level

Grab rails

- Where a concealed or high-level cistern or flush valve is used, a continuous grabrail, as specified in Cause 17, shall be provided across the rear wall and side wall nearest to the pan (AS 1428.1 Clause 15.2.7)
- Where a low-level surface mounted cistern is used, the grabrail shall be terminated at each side of the cistern (AS 1428.1 Clause 15.2.7), grabrail to extend 450mm minimum from the pan, with 50mm maximum gap between grabrail and cistern
- A back rest shall be provided, with a height at the lower edge of backrest to the top of pan seat, of 120-150 (AS 1428.1 Clause 15.2.4(b))